


Enphase Energy System with IQ Battery 5P with FlexPhase (with backup) owner's guide



Warranty

To ensure optimal performance and reliability and to meet warranty requirements, the Enphase Energy System must be installed according to the instructions in the respective product quick install guides.

The Enphase Energy System equipment is intended to operate with an internet connection. Maintaining an internet connection is important, not only for updating software and firmware but also for measuring the health of the system. Failure to maintain an internet connection may have an impact on the warranty.

In addition, features like live status monitoring, energy and power monitoring, work when the system has an active internet connection.

You can check the status of your warranty on the Enphase App by navigating to **Menu > System > Devices > Battery > Limited Warranty information**.

Visit <https://enphase.com/installers/resources/warranty> for full terms and services.

Other information

Product information is subject to change without notice. All trademarks are recognized as the property of their respective owners. User documentation is updated frequently.

Check the Enphase website (<https://enphase.com/nl-nl/installers/resources/documentation>) for the latest information.

Visit <https://enphase.com/nl-nl/patents> for Enphase patent information.

© 2025 Enphase Energy. All rights reserved.

Enphase, the e and CC logos, IQ, and certain other marks listed at

<https://enphase.com/trademark-usage-guidelines> are trademarks of Enphase Energy, Inc. in the U.S. and other countries. Data subject to change.

Audience

This manual is intended for use by owners of Enphase Energy Systems with IQ Battery 5P with FlexPhase.

Environmental protection



Waste electrical products (including batteries) should not be disposed of with household waste. Refer to your local codes for disposal requirements.



ELECTRONIC DEVICES: DO NOT THROW AWAY.
Do not install or use the Enphase Energy System equipment if it is damaged.

Enphase Energy System with IQ Battery 5P with FlexPhase



Contents

System information	6
Key components	6
Component introduction	7
IQ Battery 5P with FlexPhase	7
IQ System Controller	7
Backup profiles in Enphase Energy Systems	8
Whole home backup	8
Partial home backup	9
System monitoring and management	10
Enphase App	10
Enphase web application	10
Setting your smart profile	11
Charge battery from the grid mode	14
System care	17
Troubleshooting	18
Safety information	23
Revision history	27

Enphase Energy System



System information

Key components



IQ Battery 5P with FlexPhase

IQ Battery 5P with FlexPhase stores energy and dispatches it when you need it.

IQ Battery 5P with FlexPhase is built on a distributed architecture platform. This modular design means you can quickly and easily expand your system as your needs grow.



Enphase App

The Enphase App is a mobile app where you can monitor and control your system status from wherever you are and know exactly how much energy your solar PV system is producing. You can generate reports on energy production by day, week, month, or year.



IQ Microinverters

Under each solar panel lies an Enphase microinverter that converts DC power generated by the panel into AC power that your home can use.



IQ System Controller 3 INT

The IQ System Controller 3 INT connects home to the utility grid, IQ Battery 5P with FlexPhase, and rooftop solar. The IQ System Controller 3 INT seamlessly transitions the home energy system from grid power to backup power in the event of a utility grid failure.

Component introduction

IQ Battery 5P with FlexPhase

IQ Battery 5P with FlexPhase is an AC-coupled storage system with an energy capacity of 5.0 kWh. It houses two major components inside the cabinet, which make the IQ Battery 5P with FlexPhase powerful and reliable:

- The battery packs, internal to IQ Battery 5P with FlexPhase, store energy for later use, such as night-time or lower solar production circumstances. IQ Battery 5P can supply up to 3.84 kVA (1.28 kVA per phase) of power to the loads in your home.
- The IQ Microinverters, internal to IQ Battery 5P with FlexPhase, convert stored DC energy into usable AC electricity for your home, ensuring a reliable power supply by sharing the load.

IQ Battery 5P with FlexPhase communicates through wired communication to the IQ System Controller.



IQ System Controller

The IQ System Controller consolidates the interconnection equipment for your system. It also senses when the grid goes down and seamlessly transitions the home from grid power to backup power. During a grid outage, it safely disconnects the home from the utility grid and powers the backup loads using the IQ Battery 5P with FlexPhase storage system and the PV system.

It includes the Enphase IQ Gateway, a network communication device that collects production and performance data from IQ Series Microinverters and the IQ Battery 5P with FlexPhase.



Backup profiles in Enphase Energy Systems

Your home power supply can either be single-phase or three-phase.

- A single-phase power supply is a two-wire alternating current (AC) circuit with Line 1 and Neutral.
- A three-phase power supply is a four-wire AC circuit with Line 1, Line 2, Line 3, and Neutral. Each AC signal is 120° apart.

A typical home power supply has a voltage of 220-240 V (L-N) and frequency of a 50 Hz.

Whole home backup

Whole home backup is ideal for homeowners who want all-day whole home backup power for running appliances during a grid outage. The Enphase Energy System must be carefully sized to meet your single-phase home's specific energy needs.

Depending on your IQ Battery sizing, your Enphase Energy System may be able to sustain off-grid operation for extended periods.

Enphase Energy Systems with IQ Battery 5P with FlexPhase support the following backup configurations.


- Whole home backup
- Partial home backup

Each system configuration has three configurable smart profiles.

- Self-Consumption profile
- Full Backup profile

Want to upgrade your system?


Thanks to the modular design of the Enphase Energy System, it is easy to add additional battery capacity as your needs grow over time. Contact your Enphase installer to learn more about how you can expand your system.



Partial home backup

Single-phase partial home backup is ideal for homeowners who want to power essential appliances in their single-phase home, day or night, during a grid outage. If you have a partial home backup configuration,

your Enphase Energy System has been sized to provide power for the appliances that you identified as “essential” in discussions with your installer.



System monitoring and management

Make, use, save, and export power right from the palm of your hand with the Enphase App. You can quickly and easily monitor and control your Enphase Energy System and modify system settings directly from the Enphase App.



NOTE: Internet connectivity for your Enphase Energy System is essential to keep your system updated and provide accurate information on the Enphase App.

Enphase App

The mobile application is available for both iOS and Android devices. You can install the latest version of Enphase App from the App Store or Play Store.




Getting started

Instructions to activate your Enphase App account are sent to you at the email address you provided to your installer. Look for an email with the subject line “Activate Your Online Solar Monitoring Account.” from donotreply@enphaseenergy.com. You will also receive monthly emails from this address. Be sure to unblock this address from your spam or junk mail filters. Read the Enphase App terms of service at <https://enphase.com/nl-nl/legal/terms-service>.



Enphase web application

You can access the Enphase App using your internet browser on your desktop or mobile device. Log in to the Enphase App at <https://enlighten.enphaseenergy.com>.




Setting your smart profile

Your Enphase Energy System features three preconfigured smart profiles that allow you to choose the operation that matches your energy management objectives. You can easily change your profile as your objectives change over time.

You can set your Enphase Energy System units to one of the below smart profiles:

- Self-Consumption profile
- Full Backup profile



1

In the upper left corner of the Status section, you can see the **operating status** of your system and whether your system is **On Grid** or **Off Grid**.

2

Tap **LIVE STATUS** on the status page to see real-time energy flows for your system.


3

Your system's behavior is determined by the **smart profile** you enable.

Self-Consumption profile

Self-Consumption profile always prioritises your consumption or storage of your produced solar energy over exporting it to the grid. To complete Self-Consumption profile configuration, you must decide how much of your Enphase IQ Battery capacity will be held in reserve for backup power in case of a grid outage. This is referred to as your reserve capacity.

In jurisdictions where solar export is not allowed, your produced solar energy is never exported to the grid.



1

Select **Self-Consumption** profile if you wish to use as much as possible of your generated energy at home.

2


You can edit the **reserve capacity** of your IQ Batteries in Self-Consumption profile. The reserve capacity refers to the percentage of your battery's capacity that is reserved for outages. For example, if the reserve capacity is set to 30%, your IQ Batteries will not discharge below 30% unless there is a grid outage.

You can change your battery reserve capacity setting from the battery storage page on the Enphase App for any of the smart profile settings.


Operation in Self-Consumption profile

Normal operation in the Self-Consumption profile always prioritises the consumption of solar production or storage over export to the grid. In jurisdictions where export is not allowed (zero export regulations), energy is never exported to the grid.


During daylight hours, energy is used to power the home or charge the batteries.



During regular operation, solar production powers the home and charges the battery.



Once the battery is fully charged, solar production powers the home, and the excess solar power generated is exported to the grid.








In cases when the home is consuming more power than solar production can provide, the battery starts discharging to meet the power requirement.

Charge battery from the grid mode

Charge battery from the grid is an additional feature that you can enable to charge your battery from the grid when the energy prices are low.

To enable **Charge battery from the grid** through the Enphase App, go to **Menu > Settings > Battery**. As shown below you can schedule a time window during which your batteries can be charged from the grid. The usual practice is to enable/schedule Charge battery from the grid when the utility rates are low.





Full Backup profile

When you enable the Full Backup profile, all your Enphase Energy System capacity is held in reserve in the event of a power outage. When this profile is set, the batteries do not charge and discharge when the grid is available.

Reserve capacity

NOTE: Reserve capacity is not adjustable in the Full Backup profile. This profile is often used in areas that experience frequent grid outages without a related storm event.

- 1 Select **Full Backup** profile to store 100% of your battery energy for use during a grid outage at home.

Operation in Full Backup profile

This profile prepares your system for power outages by maintaining a full charge in the battery.

During daylight or off-peak hours, the solar production is prioritised to:

1. Charge your battery
2. Power your home
3. Export to the grid


After the battery is fully charged, electricity is imported from the grid when your home needs more power than the solar panels can provide.

When there is no sunlight, your home uses electricity from the grid.


What happens when an outage occurs?

When an outage occurs, your batteries discharge to power your home.


You can check the backup history of your device through the Enphase App, go to **Menu > System > Backup History**.



When the battery is fully charged, solar production and grid power the home.



When the grid is down and sunlight is not available, the battery powers the home.



If there is a grid outage at night, the battery will power the backed-up loads. The battery will start charging from the grid once it is back online to restore it to 100% SOC.

System care



The Enphase Energy System equipment is outdoor rated. However, it should not be immersed in water.



Do not block vents or store flammable, sparking, or explosive objects near the equipment.



Store all objects that could fall onto or collide with the unit away from the equipment.



Never rest anything on top of the equipment.



For a system installed indoors, a nearby smoke detector is recommended. For an outdoor installation, a smoke detector is not necessary.



Use a slightly damp (water only) or dry cloth to clean or dust the equipment as needed. Do not use cleaning solvents or harsh chemicals on the equipment.



Troubleshooting

System recovery after shutdown

Your system has experienced a shutdown if it is no longer providing power to your home. System shutdowns may be caused by a failure of any external wiring or accessories of the system, by a failure of the wired communication systems, or any other equipment failure related to the Enphase Energy System. Check the MCBs inside the IQ System Controller and reset them if they have tripped. Recovery steps following system shutdown vary depending on the cause of the shutdown. If solar production and grid are available and the batteries still do not recover, restart the batteries by cycling the DC switches on the IQ Battery 5P with FlexPhase unit, see [Reset the IQ Battery 5P with FlexPhase using DC switch](#).

Shutdown due to communications system failure

If your Enphase App shows "Microinverters not reporting" or "Batteries not reporting", give the system up to 15 to 20 minutes to recover on its own. The Enphase Energy System reconnects automatically and recovers from wired communication failures. If more than 20 minutes have elapsed and you do not see communication established, contact Enphase Support.

Shutdown due to System Shutdown Switch activation

The System Shutdown Switch (SSD) is used together with PV and battery breakers to disconnect all PV panels and IQ Battery 5P with FlexPhase units from the home to ensure the safety of maintenance technicians. If the SSD Switch is activated, you must follow these steps to resume operation:

- Turn the SSD Switch to the ON position.
- Turn the PV breakers in IQ System Controller 3 INT to the ON position.
- Turn the IQ Battery 5P with FlexPhase breakers in IQ System Controller 3 INT to the ON position.
- Press the DC switch on all IQ Battery 5P with FlexPhase units to turn them ON.

System shutdown using manual override switch

In the event of an emergency, follow the instructions on the manual override switch cover in the IQ System Controller to enable or disable manual override mode. When you enable manual override mode, your system bypasses the IQ Batteries and PV. The system operates with power only from the utility grid in this mode. You should perform these steps only in the event of an emergency or if you have been instructed to do so by Enphase Support.

IQ Gateway communications troubleshooting

If the IQ Gateway inside the IQ System Controller has stopped reporting to the Enphase App, see this webpage for more information <https://support.enphase.com/s/article/Reconnecting-your-Envoy-S-or-IQ-Envoy>.

If the IQ Gateway is not powered on or has failed, the IQ Battery 5P with FlexPhase units will not discharge. If the IQ Gateway fails, contact your installer to submit a warranty claim for replacement (where applicable).

The Network communications LED (LED 1) in the IQ Gateway is lit solid green when connected to the internet. If the Enphase App shows that the IQ Gateway is not reporting, and the Network communications LED on the IQ Gateway is lit red, then you may need to reconnect the IQ Gateway to the internet using Wi-Fi, hard-wired Ethernet, or a cellular network.

Check that the IQ Gateway is ON. If not, switch it ON.

For more information on how to access monitoring when there is no connectivity, visit

<https://support.enphase.com/s/article/Connecting-to-your-system-without-cell-connectivity>.

IQ System Controller 3 INT LEDs




1 LED 1

LED COLOUR	STATE	DESCRIPTION
— — —	Off	Not operating
— — —	Flashing green	Switched on; booting
————	Solid green	Operational
— — —	Flashing red	Firmware upgrade
————	Solid red	Error
— — —	Flashing blue	Operational; cannot detect any IQ Battery
————	Solid blue	Operational; cannot detect at least one IQ Battery
— — —	Flashing yellow	Performing state of charge recovery
————	Solid yellow	Off-grid

2 LED 2

LED COLOUR	STATE	DESCRIPTION
— — —	Off	Not operating
— — —	Flashing green	Switched On; booting
————	Solid green	Operational; on-grid
— — —	Flashing blue	Synchronizing to grid
————	Solid blue	Off-grid
————	Solid red	In system shutdown or manual override mode

IQ Gateway LEDs and buttons



1 NETWORK COMMUNICATION LED

LED COLOUR	LED STATUS	EVENT
	Green	IQ Gateway is connected to Enphase Installer Platform (EIP)
	Flashing green	Connecting to EIP or the Wi-Fi router
	Red	Connected to the local network only, i.e., without internet
	Off	No network is available

2 AP MODE LED

LED COLOUR	LED STATUS	EVENT
	Green	AP mode is enabled and the IQ Gateway Wi-Fi network is available
	Off	AP mode is disabled Default state unless the installer uses AP mode

3 AP MODE BUTTON

EVENT

To be used only by the installer to configure the system

Press to activate AP mode

4 POWER PRODUCTION LED

LED COLOUR	LED STATUS	EVENT
	Flashing green	An upgrade of microinverters is in progress
	Green	All microinverters are producing power
	Red	One or more microinverters have stopped producing power
	Flashing red	Microinverters are not yet detected
	Off	All microinverters have stopped producing power

Usually red at dawn/dusk, off at night, and flashing red after IQ Gateway restarts

5 DEVICE COMMUNICATION LED

LED COLOUR	LED STATUS	EVENT
	Flashing green	IQ Gateway is scanning for microinverters
	Green	All microinverters are communicating
	Red	One or more microinverters have stopped communicating
	Off	All microinverters have stopped communicating

Usually red at dawn and dusk, off at night

6 DEVICE SCAN BUTTON

EVENT


To be used only by the installer to configure the system

Press to start/stop a 15-minute scan for devices over the power line

Reset the IQ Battery 5P with FlexPhase using the DC switch









In the unlikely event that a battery does not automatically recover from a failure scenario, you can manually reset the battery to resume normal functioning.






To reset the battery, lightly press the DC switch button on the front of the battery. The battery LED state will change to a red triple flash pattern. Then, switch off the AC circuit breaker for the battery in the electrical panel and wait 30 seconds after the LED on the battery has gone off. After 30 seconds, turn on the AC circuit breaker again and wait for the battery to show a red triple flash pattern. Then, press the DC switch once again to turn on the battery. The LED state should change to green/blue.



IQ Battery 5P with FlexPhase LED status

You can check and record the colour of all the LEDs on the front of the IQ Battery 5P with FlexPhase using the following table. If the IQ Battery 5P with FlexPhase lights are solid or pulsing green or blue, the batteries are operating normally.

LED COLOUR	STATE	DESCRIPTION
	Solid yellow	Not operating due to high temperature. See Troubleshooting
	Yellow single flash	No communication with IQ Gateway
	Yellow double flash	Battery controller update in progress
	Yellow triple flash	BMS update in progress
	Yellow one-second flash	PCU update in progress
	Soft pulse yellow	Sleep mode
	Soft pulse blue	Discharging
	Solid blue or green	Idle. The colour transitions from blue to green as the state of charge increases Check the Enphase App/Enphase Installer Platform for charge status

LED COLOUR	STATE	DESCRIPTION
	Soft pulse green	Charging
	Red single flash	Upgrade fail
	Red double flash	IQ Battery 5P with FlexPhase is in an error state. Contact Enphase Support to troubleshoot the issue
	Red triple flashes	DC control switch is OFF, and AC from external source is present
	Soft pulse red	DC control switch is ON, and AC from external source is not present
	Off	DC control switch is OFF, and AC from external source is not present

When to contact Enphase Support

If your system is not operating properly, or has shut down unexpectedly or the system is locked out due to G100-related violations contact Enphase Support for guidance at <https://enphase.com/nl-nl/contact-us>.

Your support agent will ask for details on the status LEDs in your system. Be prepared to provide information about the IQ Battery 5P with FlexPhase storage system LED.

Safety information

Important safety instructions

This manual describes the safe use of the Enphase Energy System with the IQ Battery 5P with FlexPhase units for a homeowner. See the [Safety data sheet](#) for safe handling.

Safety and advisory symbols

To reduce the risk of electric shock and to ensure the safe installation and operation of the Enphase Energy System, the following safety symbols indicate dangerous conditions and important safety instructions.



DANGER!

This indicates a hazardous situation, which, if not avoided, will result in death or serious injury. Use extreme caution and follow instructions carefully.



WARNING!

This indicates a situation where failure to follow instructions may be a safety hazard or cause equipment malfunction. Use extreme caution and follow instructions carefully.



NOTE

This indicates information important for optimal system operation. Follow instructions carefully.

Safety instructions



A battery can present a risk of electrical shock, fire, or explosion from vented gases. Only qualified electricians should install, troubleshoot, or replace the Enphase Energy System equipment or wiring.



If the Enphase storage equipment generates smoke, remove AC power from the Enphase Energy System, and turn the DC switch on the IQ Battery 5P with FlexPhase units to the OFF position, following the instructions in the manual.



In case of fire, use a standard or carbon dioxide fire extinguisher or another appropriate extinguisher to put out the fire.



Do not dispose of the IQ Battery 5P with FlexPhase units in a fire or by burning.



Do not allow or place flammable, sparking, or explosive items near the Enphase storage system equipment.



Do not attempt to repair the Enphase Energy System equipment; it contains no user-serviceable parts. Do not open the IQ Battery 5P with FlexPhase unit under the cover. Doing so will void the warranty. If the Enphase Energy System equipment fails, contact your solar installation professional or Enphase at <https://enphase.com/nl-nl/contact-us>.












The IQ Battery 5P with FlexPhase unit is designed for stationary installation only. It is not designed for mobile applications such as installation on vehicles and trailers and should not be used in such applications.



During use, when stored, or during transport, keep the IQ Battery 5P with FlexPhase unit in an area that is well-ventilated, where the ambient temperature is between -20°C to 50°C (-4°F to 122°F).



Risk of electric shock. In areas where flooding is possible, install the Enphase Energy System equipment at a height that prevents water ingress.

-  Risk of equipment damage. During use, storage, transport, or installation, always keep the Enphase Energy System equipment in an upright (top side up) position.
-  Do not install or use the Enphase Energy System equipment if it has been damaged in any way.
-  Do not place beverages or liquid containers on top of the Enphase Energy System equipment. Do not immerse Enphase Energy System equipment in liquids or flooding.
-  Do not sit on, place objects on, or insert objects into the Enphase Energy System equipment.
-  Read this entire document before using Enphase Energy Systems.
-  Protection against lightning and resulting voltage surge must be in accordance with local standards.
-  Using unapproved attachments or accessories could result in damage or injury.
-  To ensure optimal reliability and to meet warranty requirements, Enphase Energy System equipment must be installed and stored according to the instructions in Enphase Energy System equipment guides.
-  IQ Battery 5P with FlexPhase is intended to operate with an internet connection. A Wi-Fi or Ethernet primary internet connection is required to ensure consistent connectivity.
During use, storage, and transport, keep Enphase storage products:
 - Properly ventilated
 - Away from heat, sparks, and direct sunlight
 - Away from excessive dust, corrosive and explosive gases, oil, and smoke
 - Away from direct exposure to gas exhaust, such as from motor vehicles
 - Free of vibrations
 - Away from falling or moving objects, including motor vehicles
 - At an elevation of lower than 2500 m (8200 ft) above sea level
- In a location compliant with fire safety regulations (has a smoke detector)
- In a location compliant with local building codes and standards

IMPORTANT SAFETY INSTRUCTIONS

SAVE THESE INSTRUCTIONS. This guide contains important instructions that you must follow during the installation and maintenance of the IQ System Controller 3 INT. Failing to follow any of these instructions may void the warranty (<http://enphase.com/warranty>).

In case of fire or other emergency

In all cases:

- If safe to do so, turn off all DC switches on each IQ Battery.
- Turn off the PV breaker and battery breakers inside the IQ System Controller 3 INT.
- Turn off the AC breaker for the IQ System Controller 3 INT circuit.
- If an isolator switch is present, switch off the AC isolator for the IQ System Controller 3 INT circuit.
- Contact the fire department or other required emergency response team.
- Evacuate the area.

In case of fire:

- When safe, use a fire extinguisher. Suitable types are A, B, and C dry chemical fire extinguishers. Additional extinguishing media include carbon dioxide or alcohol-resistant foams.


In case of flooding:


- Stay out of water if any part of the IQ System Controller 3 INT or wiring is submerged.
- If possible, protect the system by finding and stopping the source of the water and pumping it away.
- If water has contacted the unit, call your installer to arrange an inspection. If you are sure that water has never contacted the battery, let the area dry completely before use.


In case of unusual noise, smell, or smoke:

- Ensure nothing is in contact with the IQ System Controller 3 INT.
- Ventilate the room.
- Contact Enphase Support at <https://enphase.com/nl-nl/contact-us>.


Safety and advisory symbols


 **DANGER:** This indicates a hazardous situation, which, if not avoided, will result in death or serious injury.


 **WARNING:** This indicates a situation where failure to follow instructions may be a safety hazard or cause equipment malfunction. Use extreme caution and follow instructions carefully.


 **NOTE:** This indicates information particularly important for optimal system operation. Follow instructions carefully.


Safety instructions


 **DANGER:** Risk of electric shock. Risk of fire. Only qualified electricians should install, troubleshoot, or replace the IQ System Controller 3 INT.


 **DANGER:** Risk of electric shock. Risk of fire. Do not attempt to repair the IQ System Controller 3 INT. Tampering with or opening the IQ System Controller 3 INT will void the warranty. If the IQ System Controller 3 INT fails, contact your installer/Enphase Support for assistance at <https://enphase.com/nl-nl/contact-us>.


 **DANGER:** Risk of electric shock. Do not use Enphase equipment in a manner not specified by the manufacturer. Doing so may cause death or injury to persons or damage to equipment.


 **DANGER:** Risk of electric shock. Risk of fire. Do not work alone. Someone should be in the range of your voice or close enough to come to your aid when you work with or near electrical equipment.


 **DANGER:** Risk of fire. Do not allow or place flammable, sparking, or explosive items near the IQ System Controller 3 INT.


 **DANGER:** Risk of electric shock. In areas where flooding is possible, install the IQ System Controller 3 INT at a height that prevents water ingress.

 **WARNING:** Do not sit on, step on, place objects on, or insert objects into the IQ System Controller 3 INT.

 **WARNING:** Do not place beverages or liquid containers on top of the IQ System Controller 3 INT. Do not expose the IQ System Controller 3 INT to flooding.

 **NOTE:** Using unapproved attachments or accessories could result in damage or injury.

 **NOTE:** The IQ System Controller 3 INT is intended to operate with an internet connection through the built-in IQ Gateway. Failure to maintain an internet connection may have an impact on the warranty. See limited warranty for full terms and services (<http://enphase.com/warranty>).

 **NOTE:** When replacing an IQ System Controller 3 INT, you must replace it with an IQ System Controller 3 INT of the same type with the same AC current rating.

☑ **NOTE:** During use, storage, and transport, keep the IQ System Controller 3 INT:

- Properly ventilated
- Away from water, other liquids, heat, sparks, and direct sunlight
- Away from excessive dust, corrosive and explosive gases, and oil smoke
- Away from direct exposure to gas exhaust, such as from motor vehicles
- Away from falling or moving objects, including motor vehicles. If mounted in the path of a motor vehicle, we recommend a 91 cm (36 in) minimum mounting height
- In a location compliant with fire safety regulations
- In a location compliant with local building codes and standards

Revision history

REVISION	DATE	DESCRIPTION
USG-00123-1.0	April 2025	Initial release.

© 2025 Enphase Energy. All rights reserved. Enphase, the e and CC logos, IQ, and certain other marks listed at <https://enphase.com/trademark-usage-guidelines> are trademarks of Enphase Energy, Inc. in the U.S. and other countries. Data subject to change.

